

GENERAL PROJECT NOTES:

1. FOR EXACT LOCATION OF ALL ROOF OPENINGS CHECK WITH GENERAL CONTRACTOR PRIOR TO INSTALLATION.
2. ROOF-TOP SLEEPERS FOR MECHANICAL EQUIPMENT MUST BEAR ON PURLINS OR BEAMS. ROOF TOP UNITS NOT SHOWN ON DRAWINGS MUST BE LOCATED ADJACENT TO BEAM LINES UNLESS APPROVED BY ENGINEER.
3. NO HANGING LOADS ALLOWED FROM 2x4 STIFFENERS UNLESS APPROVED BY ENGINEER.
4. FOR ALL BEAMS AND LEDGER ELEVATION NOT SHOWN, SEE STRUCTURAL OR ARCHITECTURAL DRAWINGS.
5. THE STRUCTURES GROUP RECOMMENDS A MINIMUM ROOF SLOPE OF 1/4" PER FOOT FOR PROPER DRAINAGE.

SKYLIGHT & RV FRAMING:

1. SUPPORT ALL SKYLIGHTS AND RV'S W/ 4x4 #2 STIFFENERS IN SIMPSON "F44" HANGERS.

MECHANICAL UNIT SUPPORTS:

- AC: 2274 LBS. MAX. SUPPORT PER DTL 16/SG-202  
AC: 750 LBS. MAX. SUPPORT PER DTL 15/SG-202

MAXIMUM TEMPORARY CONSTRUCTION LOADS:


- 2x STIFFENER.....NONE  
8" O.C. PURLIN.....75 P.L.F.  
GLU-LAM BEAM OR GIRDER.....200 P.L.F.

NAILING SCHEDULE (10d COM.x 2 1/4")

AREA	BOUNDARY & CONT. EDGE	STAGGERED EDGE	COMMENT
A	6" O.C.	6" O.C.	TYPICAL (U.O.N.)
B	4" O.C.	6" O.C.	SEE PLAN
C	2 1/2" O.C.	4" O.C.	SEE PLAN
D	-	-	NOT USED

NAILING SCHEDULE NOTES:

1. NAILING @ INTERMEDIATE SUPPORTS TO BE 12" O.C.
2. BOUNDARY NAILING REQ'D. @ STRUTS, WALL TIES & OPN'GS.
3. (2) ROWS B.N. TO BEAMS FIRST 3 BAYS FROM WALL.
4. AREA "A" TYPICAL. (U.O.N.)
5. NAIL SPACING LESS THAN 3" TO BE IN 3x OR WIDER MEMBER & STAGGERED PER DETAIL ON SG-201



ROOF FRAMING PLAN

SCALE: 1/16" = 1'-0"

© The Structures Group 2020  
THIS DRAWING IS THE PROPERTY OF THE STRUCTURES GROUP, INC. NO REPRODUCTION OR REUSE OF THIS DRAWING IS ALLOWED WITHOUT THE WRITTEN PERMISSION OF THE STRUCTURES GROUP, INC.

The Structures Group  
Southwest, Inc.  
5601 West Van Buren - Phoenix AZ 85043 - (602) 269 2458  
www.structuresgroup.com

VIP PRODUCTS  
GOODYEAR, ARIZONA

SG-101

4018  
10FEB21  
14MAY21

DELTA 1 - CITY CORRECTIONS / COORDINATIONS

BALMER  
architectural group

SUN STATE  
BUILDERS

THIS DRAWING IS AN INSTRUMENT OF SERVICE AND IS THE PROPERTY OF BALMER ARCHITECTURAL GROUP, INC. THIS DRAWING MAY NOT BE REPRODUCED OR REUSED WITHOUT THE WRITTEN PERMISSION OF BALMER ARCHITECTURAL GROUP, INC. 2425 E. CAMERON RD., SUITE 775 PHOENIX, ARIZONA 85016 PH: 602-954-6718 FAX: 602-488-9880 E-MAIL: ADMIN@BAG-INC.COM

EXPIRES 06-30-2022