


**ELECTRICAL OVERALL FLOOR PLAN**

SCALE: 1/16" = 1'-0"



**ENLARGED ELECTRICAL OWNER'S ROOM**

SCALE: 1/8" = 1'-0"



**KEYED NOTES**

- 1 REFER TO ENLARGED FLOOR PLANS, SHEET E-300, FOR ADDITIONAL INFORMATION.
- 2 ELECTRICAL SERVICE ENTRANCE SECTION.
- 3 PANEL "HP". VERIFY ELECTRICAL EQUIPMENT WILL HAVE PROPER WORKING SPACE PER NEC 110.26.
- 4 30KVA STEP DOWN TRANSFORMER. VERIFY ELECTRICAL EQUIPMENT WILL HAVE PROPER WORKING SPACE PER NEC 110.26.
- 5 PANEL "LP". VERIFY ELECTRICAL EQUIPMENT WILL HAVE PROPER WORKING SPACE PER NEC 110.26.
- 6 4"x8"x3/4" PLYWOOD TELEPHONE MOUNTING BOARD "TMB" WITH (1) #6 BOND TO BUILDING STEEL PER NEC ARTICLE 800. EXTEND (4) 4" EMPTY CONDUITS FROM MAIN TMB. VERIFY LOCATION AND REQUIREMENTS PRIOR TO ROUGH-IN.
- 7 FIRE ALARM CONTROL PANEL (F.A.C.P.). VERIFY EXACT LOCATION PRIOR TO ROUGH-IN.
- 8 FIRE ALARM BELL. VERIFY EXACT LOCATION PRIOR TO ROUGH-IN.
- 9 REFER TO ENLARGED FLOOR PLAN, THIS SHEET, FOR ADDITIONAL INFORMATION.
- 10 PROVIDE (11) 3" EMPTY CONDUITS OUT OF SES, PAST THE OWNERS ROOM AND STUB UP FOR FUTURE USE. COORDINATE EXACT STUB UP LOCATIONS WITH OWNER PRIOR TO ROUGH-IN.
- 11 ELECTRIC UNIT HEATER - 208V 1ø 3kW, PROVIDE WITH THERMOSTAT. PROVIDE HEAVY DUTY 30AMP 240V 2P2F NEMA 1 DISCONNECT SWITCH.
- 12 ROOF MOUNTED EXHAUST FAN - 480V 3ø 2HP (3.4FLA). FAN TO BE INTERLOCKED WITH FIRE PUMP. FAN SHALL RUN WHEN FIRE PUMP OPERATES. PROVIDE HEAVY DUTY 30AMP 600V 3P3F NEMA 1 DISCONNECT AND PROVISIONS FOR INTERFACE WITH FIRE PUMP.
- 13 FEEDER SHALL NOT BE ROUTED THROUGH THE BUILDING. EITHER SURFACE MOUNTED ON THE EXTERIOR OR UNDERGROUND PER NEC 695.
- 14 ELECTRICAL JOCKEY PUMP CONTROL PANEL (480V/3ø, 2.0HP, 3.4FLA). PROVIDE (3) #12's Cu., (1) #12 Cu. E.G. - 3/4" C.
- 15 FIRE PUMP DISCONNECT SWITCH. SEE ONE-LINE DIAGRAM, SHEET E-500, FOR ADDITIONAL INFORMATION AND REQUIREMENTS. PROVIDE MOTOR RATED SWITCH AS LOCAL DISCONNECT MEANS.
- 16 ELECTRICAL FIRE PUMP CONTROLLER (BY OTHERS) 480V/3ø, 100 H.P., 124 FLA, 725 LRC. SEE ONE-LINE DIAGRAM, E-4, FOR ADDITIONAL INFORMATION AND REQUIREMENTS.
- 17 FORKLIFT CHARGER - PROVIDE HEAVY DUTY 600V 30A 3P3F NEMA 1 DISCONNECT SWITCH (480V 3ø 9.6FLA). VERIFY EXACT LOCATION AND MOUNTING WITH OWNER PRIOR TO ROUGH-IN.
- 18 120V 1ø 10FLA RECEPTACLE FOR PALLET WRAP MACHINE. VERIFY EXACT LOCATION AND MOUNTING WITH OWNER PRIOR TO ROUGH-IN.
- 19 120V 20A HVAC MAINTENANCE GFCI PER NEC 210.63 WITH WHILE-IN-USE COVER. ELECTRICAL CONTRACTOR SHALL TIE ROOFTOP RECEPT INTO CIRCUIT "LSW"-25. TYPICAL OF (2) LOCATIONS.
- 20 120V 20A HVAC MAINTENANCE GFCI PER NEC 210.63 WITH WHILE-IN-USE COVER. ELECTRICAL CONTRACTOR SHALL TIE ROOFTOP RECEPT INTO CIRCUIT "LSM"-1. TYPICAL OF (2) LOCATIONS.
- 21 120V 20A HVAC MAINTENANCE GFCI PER NEC 210.63 WITH WHILE-IN-USE COVER. ELECTRICAL CONTRACTOR SHALL TIE ROOFTOP RECEPT INTO CIRCUIT "LSE"-29. TYPICAL OF (3) LOCATIONS.
- 22 OVERHEAD DOOR OPERATOR - 480V, 3ø, 6FLA (VERIFY EXACT ELECTRICAL REQUIREMENTS AND LOCATIONS PRIOR TO ROUGH-IN). PROVIDE HEAVY DUTY 30AMP 600V 3P3F NEMA 1 DISCONNECT SWITCH. TYPICAL OF (10) LOCATIONS.
- 23 FOURPLEX FOR 120V 1ø 6FLA DOCK LEVELER. VERIFY EXACT LOCATION, MOUNTING AND REQUIREMENTS WITH MANUFACTURER PRIOR TO ROUGH-IN. TYPICAL OF (10) LOCATIONS.
- 24 PANEL "HSM".
- 25 75KVA STEP DOWN TRANSFORMER.
- 26 PANEL "LSM".

**VOLTAGE DROP NOTE:**

1. ALL 120V RECEPTACLE CIRCUITS LONGER THAN 125'-0" SHALL BE #10 CU. IN 3/4" CONDUIT UNLESS NOTED OTHERWISE.
2. ALL 120V RECEPTACLE CIRCUITS LONGER THAN 160'-0" SHALL BE #8 CU. IN 3/4" CONDUIT UNLESS NOTED OTHERWISE.
3. ALL 120V RECEPTACLE CIRCUITS LONGER THAN 240'-0" SHALL BE #6 CU. IN 1" CONDUIT UNLESS NOTED OTHERWISE AND REDUCE TO #8 CU. AT THE CIRCUIT BREAKER.
4. ALL 120V RECEPTACLE CIRCUITS LONGER THAN 370'-0" SHALL BE #4 CU. IN 1" CONDUIT UNLESS NOTED OTHERWISE AND REDUCE TO #8 CU. AT THE CIRCUIT BREAKER.

THIS DRAWING IS AN INSTRUMENT OF SERVICE AND IS THE PROPERTY OF BALMER ARCHITECTURAL GROUP INC. THIS DRAWING MAY NOT BE REPRODUCED NOR REPRODUCTION HEREOF USED, WITHOUT THEIR WRITTEN PERMISSION. © 2021 BALMER ARCHITECTURAL GROUP, INC. 2425 E. CAMELBACK RD., SUITE 775 PHOENIX, ARIZONA 85016 P: 602-954-8718 FAX: 602-488-9880 E-MAIL: ADMIN@BAG-INC.COM



**SUN STATE**  
BUILDERS

**VIP PRODUCTS**  
GOODYEAR, AZ.  
ELECTRICAL OVERALL WAREHOUSE PLAN

**E-200**  
40012.010  
24FEB21  
CITY COMMENTS  
14MAY21

**BALMER**  
architectural group

**DESIGN CODES**  
IECC, 2018    NEC, 2017

**ELECTRICAL CONTRACTOR SHALL NOTIFY DESIGNER/ENGINEER PRIOR TO ANY DEVIATION FROM THIS SET OF ELECTRICAL DESIGN PLANS. ANY CHANGES TO THE DESIGN, IF APPROVED BY ENGINEER, WILL REQUIRE REVISIONS TO PLANS AND POSSIBLE ADDITIONAL SERVICE FEE.**

Project Contact/Designer: **MINDY ADLER**  
Project # 21058  
**HAWKINS DESIGN GROUP INC.**  
ELECTRICAL CONSULTING ENGINEERS  
140 WEST HARWELL ROAD  
GILBERT, ARIZONA 85233  
P: 480.813.9000 FAX: 480.813.9001  
EMAIL: email@hwdsg.com

All concepts, designs and data indicated on these drawings are the sole property of the Hawkins Design Group Inc., and shall not be used for any other purpose other than originally intended without written permission of the engineer.

IF DRAWING IS NOT PLOTTED AT 24 X 36 THEY ARE NOT FULL SIZE