



1. ALL INSULATING MATERIALS SHALL HAVE A FLAME SPREAD RATING NOT TO EXCEED 25 AND A SMOKE DENSITY NOT TO EXCEED 450, WHEN TESTED IN ACCORDANCE WITH ASTM E 84.
2. COMPARE ALL WALL AND BUILDING SECTIONS FOR TYPICAL NOTES AND DETAILS.
3. SEE STRUCTURAL DRAWINGS FOR TYPICAL STRUCTURAL NOTES AND DETAILS.
4. SEE SHEET A-103 FOR ROOFING MATERIALS AND ROOF INSULATION, TYPICAL.




VIP PRODUCTS
GOODYEAR, AZ.
WALL SECTIONS

A-303
40012.010
25MAR21




6 WALL SECTION

SCALE 3/8" = 1'-0"




5 WALL SECTION

SCALE 3/8" = 1'-0"




4 WALL SECTION

SCALE 3/8" = 1'-0"




3 WALL SECTION

SCALE 3/8" = 1'-0"



2 WALL SECTION

SCALE 3/8" = 1'-0"



1 WALL SECTION

SCALE 3/8" = 1'-0"